

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7165-1574:122 Page 1 of 1

**CATEGORY:** Control Units (Non High-Rise)

**LISTEE:** ADT Security Services, Inc., 695 Route 46 West, Suite 200, Fairfield NJ 07004  
Contact: Ron Dalton (310) 725-2972 Fax (310) 725-2942

**DESIGN:** Model FireShield series fire alarm control units. Models FS302G, FS302R, FS302G-2, FS302GF, FS502G, FS502R, FS502G-2, FS502GF, FS1004G, FS1004R, FS1004G-2 and FS1004GF. Model FSDACT digital alarm communicator transmitter. Local, auxiliary, \*central station, remote station, automatic, manual, waterflow and sprinkler supervisory service. Refer to the listee's data sheet for detailed product description and operational considerations.

**RATING:** 120 VAC Primary, 24 VDC Secondary

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating, and UL label.

**APPROVAL:** Listed as fire alarm control units for use with separately listed compatible initiating and indicating devices. Refer to listee's Installation Instructions Manual for details.

\*These control units can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation signal (for total evacuation) in accordance with NFPA 72, 1999 Edition.

**NOTE:** For **Fire Alarm Verification Feature** (delay of fire alarm signal), the maximum Retard/Reset/Restart period shall not exceed 30 seconds.

**XLF:** 7165-1591-102

\*Rev. 07-31-03KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JULY 31, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**